Plumbing Pressure Test Memorandum

1

and the second state of the second states	
Issued by: (Plumber)	Hayden Ballantyne Registration Number: 22698
Company Name:	On Tap Plumbing Ltd
Company Address:	56c Rowe Road Whatawhata
Company Contact Details: Ph:	Mb: 0274514181 Fx:
To:	Mamilton City Council 🔲 Hauraki District Council 🗌 Matamata-Piako District Council 🔲 Otorohanga District Council 🗍 Thames-Coromandel District Council 🗍 Waikato District Council 🗍 Waipa District Council 🗍 Waitomo District Council
Building Consent Number:	
Building Owner:	Vacant
Project Address:	84 Albert Street Hamilton East Waikato
Description of Building Work:	Completion of a pressure test on the plumbing system
Scope of work covered by statement:	Water pipework replace at 84 Albert Street, old black Dux Secura system replaced with new grey polybute water piping. We certify that the system was tested to 1500kpa for a period of 30 minutes. This test was conducted in accordance with manufacturer recommendations and complies with the pressure testing provisions of the New Zealand Building Code and Approved Solution G12 AS1 and AS/NZS3500.1.2 as appropriate.
	I understand that this Statement, if accepted, may be relied upon for the purpose of establishing compliance with the Building Code and Building Consent.
Signed by: (Plumber)	12112023 Date: 8-11-2023

The Waikato Building Consent Group Producer Statement Author register is held by the Waikato Building Consent Group, Email: info@buildwaikato.co.nz For information on the Waikato Building Consent Group visit the <u>Build Waikato</u> website.